DATASHEET - AZ-3-C125



Miniature circuit breaker (MCB), 125A, 3p, C-Char

Part no. AZ-3-C125

211811

EL Number 1601053

(Norway)

(Norway)	
General specifications	
Product name	Eaton Moeller series xEffect - AZ MCB
Part no.	AZ-3-C125
EAN	4015082118112
Product Length/Depth	90 millimetre
Product height	75 millimetre
Product width	81 millimetre
Product weight	0.658 kilogram
Compliances	RoHS conform
Certifications	IEC 61373 EN45545-2 IEC/EN 60947-2
Product Tradename	xEffect - AZ MCB
Product Type	MCB
Product Sub Type	None
Delivery program	
Application	xEffect - Switchgear for industrial and advanced commercial applications Switchgear for industrial and advanced commercial applications
Number of poles	Three-pole
Number of poles (total)	3
Number of poles (protected)	3
Tripping characteristic	С
Release characteristic	С
Amperage Rating	125 A
Туре	Miniature circuit breaker AZ
Technical Data - Electrical	
Voltage type	AC
Voltage rating	230 V AC / 400 V AC
Voltage rating at DC	60 V DC (per pole)
Rated operational voltage (Ue) - max	400 V
Rated insulation voltage (Ui)	440 V
Rated impulse withstand voltage (Uimp)	4 kV
Frequency rating - min	50 Hz
Frequency rating - max	60 Hz
Rated switching capacity (IEC/EN 60947-2)	15 kA
Operational switching capacity	20 kA
Rated short-circuit breaking capacity (EN 60898) at 230 V	0 kA
Rated short-circuit breaking capacity (EN 60898) at 400 V	0 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 230 V	15 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 400 V	15 kA
Admissible back-up fuse - max	200 A gL/gG
Selectivity class	3
Lifespan, electrical	10000 operations
Overvoltage category	III
Pollution degree	2
Direction of incoming supply	As required
Technical Data - Mechanical	
Frame	45 mm

Within in number of modular spacings Built in depth Mounting width per pole Mounting width per pole Mounting width per pole Mounting width Mounting width Degree of procection Fire pole of the product of the pole of the pole of the pole of the pole of the product of the pole of the product of the pole of the p	F. 1	00
Build-indigatify with any pole Munified with the pole Munified with Munified Mu	Enclosure width	90 mm
Meurony wide project Meurony wide year of primerian Meurony Mercod Degree of primerian Training tips and bottoms Degree of primerian Connectable conductor cross section (sold-core) - nan Connectable conductor c	· •	
Mounting width Mounting Method	·	
Mouseing Method Degree of protection Decreemants consider cross section (said-card) - min Conventable conductor cross section		
Designe of pracection Terminals rings and bettern) Commendate conductor cross section tools'd-siny'- min Commendate conductor cross section fronti-d-siny'- min Commendate conductor cross section (multi-wiref)- min Commendate c	•	
Particulated biop and battomin District remains	·	
Commerciable conductor cross section (salif-care) - min Commerciable conductor cross section (salif-care) - max So man' Commerciable conductor cross section (salif-care) - max So man' Commerciable conductor cross section (salif-wared - max So man' Commerciable conductor cross section (salif-wared - max So man' Commerciable conductor cross section (salif-wared - max So man' Commerciable conductor cross section (salif-wared - max So man' Commerciable conductor cross section (salif-wared - max So man' Commerciable conductor cross section (salif-wared - max Commerciable conductor cross s		IP40 (when fitted)
Commerchable conductor cross section insult-wined in in 2.5 min² Commerchable conductor cross section insult-wined in in 2.5 min² Turniand capacity (control cable) Turniand capacity (control cable) Paging and hand touch safe, DGIV VS3, EN 50224 Paging verification as per IEC/EN 61439 - technical data Rand deparational current for spacefied their dissipation (in) Rand deparational current for spacefied their dissipation (in) Rand deparational current for spacefied their dissipation (in) Rand deparation current for spacefied their dissipation (in) Rand deparation current for spacefied their dissipation (in) Rand deparation current deparation Rand deparation current deparation Rand deparation current deparation Rand bear spacefied their deparation of their dissipation current deparation Rand bear spacefied their dissipation capacity Randbear spacefied temperature - minx Design verification as per IEC/EN 61439 10.2.2 Corrasion resistance Meets the product standard's requirements. Randbear spacefied temperature - minx Design verification as per IEC/EN 61439 10.2.2 Verification of resistance of insulating materials to normal head Randbear spacefied temperature - minx Randbear spacefied temperature - minx Randbear spacefied their dissipation of insulating materials to normal head Randbear spacefied their dissipation of insulating materials to normal head Randbear spacefied temperature - minx Randbear spacefied their dissipation of insulating materials to normal head Randbear spacefied their dissipation of their dissipation of insulating materials to normal head Randbear spacefied their dissipation of insulating materials to normal head Randbear spacefied their dissipation of	Terminals (top and bottom)	
Connectable conductor cross section (multi-wired - max Connectable conductor cross section (multi-wired - max Connectable conductor cross section (multi-wired - max Torminal capacity (control cable) Torminal protection Design verification as per IEC/EN 61439 - technical data Relad operational current for specified heat dissipation (in) Relad operational current dependent Stutin heat dissipation, one-current-dependent Stutin heat dissipation, one-current-dependent Wheat dissipation capacity Wheat dissipation and behavior and wheat the product standard's requirements. Wheat the pro		
Connectable control capeally common caleing Terminal capeally (control caleing) Terminal capeally (control capeally) Terminal capeally (control	Connectable conductor cross section (solid-core) - max	
Terminal capacity (control cable) Persign verification as per IEC/EN 61439 - technical data Rated operational current for specified heat dissipation (in) Heat dissipation per pole, current dependent Equipment heat dissipation, concurrent-dependent So 57 W State heat dissipation, concurrent-dependent Wheat dissipation per pole, current dependent Wheat dissipation capacity OW Ambient operating temperature - min Pole Corresion resistance Design verification as per IEC/EN 61439 102.22 Foreign or resistance 102.31 Verification of thermal stability of onclosures 102.32 Verification of thermal stability of onclosures 102.32 Verification of resistance of mainting materials to normal heat 102.33 Resistance to ultra violent (UV) radiation 102.24 Sections of resistance of uniquing materials to normal heat 102.25 Infinity Operand apply, since the entire switchipper medis to be evaluated. Meets the product standard's requirements. 102.25 Infinity on the ministry of the continuation of the section of	Connectable conductor cross section (multi-wired) - min	2.5 mm ²
Terminal protection Design verification as per IEC/EN 61439 - tochnical data Ruted operational current for specified heat dissipation in Next dissipation, current-dependent Equipment heat dissipation, current-dependent OW Static heat dissipation, current-dependent OW Ambient operating temperature - min Ambient operating temperature - min Ambient operating temperature - min Ambient operating temperature - max Design verification as per IEC/EN 61439 102.2 Correson resistance Meets the product standard's requirements. 102.31 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.32 Verification of resistance of insulating materials to normal heat 102.33 Resistance to ultra-violet (UV) radiation 102.5 Lifting Does not apply, since the entire switchpase needs to be evaluated. 102.5 Exciptions Meets the product standard's requirements. 102.5 Exciptions Meets the product standard's requirements. 102.5 Internal electric of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchpase needs to be evaluated. 102.5 Internal electric and ultra-violet (UV) radiation Meets the product standard's requirements. Does not apply, since the entire switchpase needs to be evaluated. 102.5 Exciptions of protection of assemblies Does not apply, since the entire switchpase needs to be evaluated. Meets the product standard's requirements. 103.0 Percencion against electric shock Does not apply, since the entire switchpase reads to be evaluated. 104.0 Examences and croppage distances Meets the product standard's requirements. 105.0 Percencion and compage distances Meets the product standard's requirements. 106.1 Descriptions of vertical products standard's requirements. 107.1 Internal electric sc	Connectable conductor cross section (multi-wired) - max	50 mm ²
Design verification as per IEC/EN 61439 - technical data Rated operational current for specified heat dissipation (In) Heat dissipation per pole, current-dependent Static heat dissipation, non-current-dependent Static heat dissipation, non-current-dependent OW Static heat dissipation, non-current-dependent OW Ambient operating temperature - min Ambient operating temperature - max Design verification as per IEC/EN 61439 10.22 Corresion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Perification of thermal stability of enclosures Meets the product standard's requirements. Meets the product standard's requirements. 10.23.2 Perification of resistance of insulating materials to normal heat 10.23 Resist, of insul, mat, to abnormal heat/Ifthe by internal elect, offects Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. 10.25 Lifting Does not apply, since the entire workchaper needs to be evaluated. Meets the product standard's requirements. 10.25 Internal electrical circuits and components Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire workchaper needs to be evaluated. Meets the product standard's requirements. 10.3 Power of protection of assemblies Does not apply, since the entire workchaper needs to be evaluated. Meets the product standard's requirements. 10.3 Instranal electrical circuits and components 10.3 Power frequency electric strongth 10.4 Power frequency electric strongth 10	Terminal capacity (control cable)	2.5 mm² - 50 mm²
Restor operational current for specified heat dissipation (III) Heat dissipation per pole, current-dependent State heat dissipation, non-current-dependent OW Ambient operating temperature - min Ambient operating temperature - min - 25°C Ambient operating temperature - min - 25°C Design verification as per IEC/EN 61439 102.2 Oronsion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures 102.3.1 Verification of thermal stability of enclosures 102.3.2 Sesist, of insul, mat. to abnormal heat? 102.3.2 Sesist, of insul, mat. to abnormal heat? 102.3.2 Sesist of insul, mat. to abnormal heat? 102.3.2 Sesist of insul, mat. to abnormal heat? 102.3.2 Inscriptions Des not apply, since the entire switchpaer needs to be evaluated. 102.3 Exercised of protection of assemblies 102.3 Exercised of protection of assemblies 103.0 Regree of protection of assemblies 104.1 Clearances and creepage distances 105.4 Clearances and creepage distances 105.4 Clearances and creepage distances 106.5 Receptors of every exercise should be evaluated. 107.1 Internal electrical circuits and connections 108.6 Receptors of external conductors 109.6 Receptors of external conductors 109.6 Receptors of external conductors 100.7 Internal electrical circuits and connections 100.8 Repeated on the entire switchpaer needs to be evaluated. 101.1 Short-circuit rating 109.8 Feet and builder's responsibility. 109.8 Feet may builder's responsibility. 109.8 Feet may builder's responsibility. 109.8 Feet may builder's responsibility. 109.9 Feet may builder's responsibility. 109.9 Feet may builder's responsibility. 109.9 Feet may builder's responsibility. 109.1 Feet may be builder's responsibility. 109.1 Feet responsibility. 109.1 Feet responsibility. 109.2 Feet responsibility. 109.2 Feet responsibility. 109.3 Mechanical function 109.4 Feet responsibility. 109.4 Feet responsibility. 109.5 Feet responsibility. 109.6 Feet responsibility. 109.6 Feet responsibility. 109.6 Feet responsibility. 109.7 Feet responsib	Terminal protection	Finger and hand touch safe, DGUV VS3, EN 50274
Heat dissipation per pole, current-dependent Spiror W Static heat dissipation, non-current-dependent OW Heat dissipation, non-current-dependent OW Ambient operating temperature - min Ambient operating temperature - min Ambient operating temperature - min Ambient operating temperature - max Spiror Design verification as por IEC/EN 61439 10-22 Corrosion resistance Meets the product standard's requirements. 10-23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10-23.2 Verification of resistance of insulating materials to normal heat 10-23.2 Verification of resistance of insulating materials to normal heat 10-23.3 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10-24 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10-25 Mechanical impact 10-25 Mechanical impact 10-26 Mechanical impact 10-27 Inscriptions Meets the product standard's requirements. 10-28 Despiror of protection of assemblies 10-29 Operand assemblies Meets the product standard's requirements. 10-29 Protection against electric assemblies Meets the product standard's requirements. 10-29 Operand assemblies Meets the product standard's requirements. 10-29 Despiror apply, since the entire switchgear needs to be evaluated. 10-20 Des not apply, since the entire switchgear needs to be evaluated. 10-20 Des not apply, since the entire switchgear needs to be evaluated. 10-21 Inscriptions Meets the product standard's requirements. 10-22 Protection against electric stock Does not apply, since the entire switchgear needs to be evaluated. 10-23 Protection against electric stock Does not apply, since the entire switchgear needs to be evaluated. 10-24 Protection against electric stock Does not apply, since the entire switchgear needs to be evaluated. 10-25 Protection against electric stock Does not apply, since the entire switchgear needs to be evaluated. 10-27 Protection against electric stock Does not apply, since the entire switchgea	Design verification as per IEC/EN 61439 - technical data	
Equipment heat dissipation, current-dependent Static heat dissipation, current-dependent West dissipation capacity Ambient operating temperature - min Ambient operating temperature - min 25°C Design verification as por IEC/EN 61439 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (IV) radiation 10.2.5 Ifficial impact 10.2.5 Ifficial impact 10.2.5 Mechanical impact 10.2.7 Internal electrical of a seemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Connections of oswerhing devices and components 10.7 Internal electrical circuits and connections 10.8 Interpretation of swerthing devices and components 10.9 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connections 10.10 Timerary transity of insulating material 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Special features Additional equipment possible Anbient temperature int a 1 °C increase results in a 0.5% linear reduction of curront carrying capocity 42	Rated operational current for specified heat dissipation (In)	125 A
Static heat dissipation, non-current-dependent Heat dissipation capacity Ambient operating temperature - min 25 °C Ambient operating temperature - max 55 °C Design verification as per IEC/EN 61439 10.2.2 Corresion resistance 10.2.3.1 Verification of resistance of imulating materials to normal heat 10.2.3.2 Verification of resistance of imulating materials to normal heat 10.2.3.2 Nerification of resistance of imulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by informal elect. effects 10.2.4 Resistance to ultra-violet (LVI) rediation 10.2.4 Resistance to ultra-violet (LVI) rediation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.1 Resistance of insulating administration of the materials to the evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and crepapie distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and components 10.8 Incorporation of switching devices and components 10.9 Timernal electrical circuits and components 10.1 Timernal electrical circuits and components 10.2 Connections for external conductors 10.3 Timernal electrical circuits and components 10.4 Timernal electrical circuits and components 10.5 Timernal electrical circuits and components 10.6 Connections for external conductors 10.8 Timernal electrical circuits and components 10.9 Timernal electrical circuits and components 10.1 Timernal electrical circuits and components 10.1 Timernal electrical circuits and components 10.1 Timernal electrical circuits and	Heat dissipation per pole, current-dependent	0 W
Heat dissipation capacity Ambient operating temperature - min Ambient operating temperature - max Design verification as per IEC/EN 61439 10.2.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.3 Experiments. 10.2.4 Resistance to ultra-violet (IV) radiation 10.2.5 Lifting 10.2.6 Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (IV) radiation 10.2.5 Lifting 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions 10.8 Operation of resistance of ultra-violet (IV) radiation 10.9 September of protection of assemblies 10.9 Foreaction against electric shock 10.9 September of protection of assemblies 10.4 Clearances and creepage distances 10.8 Protection against electric shock 10.9 Frotection signification devices and components 10.9 Frotection signification dev	Equipment heat dissipation, current-dependent	35.67 W
Ambient operating temperature - min Ambient operating temperature - max Design verification as per IEC/EN 61439 10.22 Corrosion resistance 10.23.1 Verification of hermal stability of encleaures 10.23.2 Verification of hermal stability of encleaures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.3 Resistance to ultra-violet ILV1 radiation 10.25 Lifting 10.25 Lifting 10.25 Lifting 10.25 Lifting 10.25 Lifting 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.28 Despend of protection of assemblies 10.29 Inscriptions 10.3 Despread of respended distances 10.40 Personance and creepage distances 10.50 Protection against electric abnock 10.60 Incorporation of switching divides and comections 10.70 Internal electrical circuits and connections 10.81 Connections for external conductors 10.82 Power-founder, electric strength 10.82 Power-founder, electric strength 10.83 Impulse withstand voltage 10.94 Testing of enclosures made of insulating material 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Internal electric dissipation data in the switchgear must be observed. 10.16 Temperature rise 10.17 Internal electrical circuits and connections 10.18 the panel builder's responsibility. 11 the panel builder's responsibility. 12 the panel builder's responsibility. 13 the panel builder's responsibility. 14 the panel builder's responsibility. 15 the panel builder's responsibility. 16 the panel builder's responsibility. 17 The panel builder's responsibility. 18 the panel builder's responsibility. 19 Separate must be observed. Additional equipment possible 20 Additional equipment possible 21 Additional equipment possible 22 Addit	Static heat dissipation, non-current-dependent	0 W
Design verification as per IEC/EN 61439 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Resists of insul. mat. to abnormal heat/first by internal elect. effects 10.2.3 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Michanical impact 10.2.7 Inscriptions 10.3.0 Degree of protection of assemblies 10.3.0 Person and prepaga distances 10.4 Degree of protection of assemblies 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.1 Internal electrical circuits and connections 10.3 Impure withstand voltage 10.4 Testing of enclosures made of insulating material 10.1 Internal electric strength 10.2 Internal electric strength 10.3 Impure withstand voltage 10.4 Testing of enclosures made of insulating material 10.1 Impurature rise 10.3 Impure withstand voltage 10.4 Testing of enclosures made of insulating material 10.1 Testing of enclosures made of insulating material 10.1 Impure the entire switchpear needs to be evaluated. 10.1 Internal electric strength 10.2 Internal electric strength 10.3 Impure withstand voltage 10.4 Testing of enclosures made of insulating material 10.5 Testing of enclosures made of insulating material 10.6 Temperature rise 10.7 The panel builder's responsibility. 10.8 The panel builder's responsibility. 10.9 Temperature rise 10.1 Electromagnetic compatibility 10.1 Electromagnetic compatibility 10.2 Electromagnetic compatibility 10.3 Impure the entire switchpear must to observed. 10.4 Additional information 2. The device meets the requirements, provided the information in the instruction leafer (IL) is observed. 3. Additional equipment possible 4. Additional equipm	Heat dissipation capacity	0 W
Design verification as per IEC/EN 61439 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thormal stability of enclosures Moets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.3 Resistance to ultra-violet (IVI) radiation Meets the product standard's requirements. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Connections of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electric switchgear needs to be evaluated. 10.1 Thermal electric strength 10.2 Internal electric strength 10.3 Impulse withstand voltage 10.4 Teaching of enclosures made of insulating material 10.5 Teaching of enclosures made of insulating material 10.6 Temperature rise The panel builder's responsibility. 10.7 Teaching of enclosures made of insulating material 10.8 Teaching of enclosures made of insulating material 10.9 Temperature rise The panel builder's responsibility. 10.1 Electromagnetic compatibility 10.2 Electromagnetic compatibility 10.3 Meets the product standard's requirements, provided the information in the instruction leaflet (IU) is observed. Additional information Current limiting class Features Additional equipment possibile Ambient temperature hint: a 1 "C increase r	Ambient operating temperature - min	-25 °C
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.8 Verification of resistance of insulating materials to normal heat 10.2.3.8 Resist of insul. mat to abnormal heat/fire by internal elect. effects 10.2.3.8 Resist of insul. mat to abnormal heat/fire by internal elect. effects 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Interiptions 10.2.7 Inscriptions 10.3.0 Regree of protection of assemblies 10.3.0 Pergree of protection of assemblies 10.4 Resistances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal el	Ambient operating temperature - max	55 °C
10 2.3.1 Verification of thermal stability of enclosures 10 2.3.2 Verification of resistance of insulating materials to normal heat 10 2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10 2.4 Resistance to ultra-violet (UV) radiation 10 2.5 Lifting	Design verification as per IEC/EN 61439	
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (LIV) radiation 10.2.5 Lifting 10.2.5 Liftin	<u> </u>	Meets the product standard's requirements.
10.2.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Egree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.4 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impuse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic competibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances 10.15 Forter inmitting class 10.16 Incorporation of switching devices and components 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Incorporation of switching devices and components 10.9 Incorporation of switching devices and components 10.9 Incorporation of switching devices and components 10.9 End to the entire switchgear needs to be evaluated. 10.10 End to the entire switchgear needs to be evaluated. 10.11 Short-circuit rating 1 Is the panel builder's responsibility. 10.12 Electromagnetic competibility 10.15 Electromagnetic competibility 11.15 Electromagnetic competibility 12.15 Electromagnetic competibility 13.16 Electromagnetic competibility 14.17 Electromagnetic competibility 15.18 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Electromagnetic competibility 11.17 Electromagnetic competibility 12.18 Electromagnetic competibility 13.19 Electromagnetic competibility 14.19 Electromagnetic competibility 15.19 Electromagnetic competibility 16.19 Electromagnetic competibility 17.19 Electromagnetic competibility 18.19 Electromagnetic competibility 19.19 Electromagnetic competibility 19.19 Electromagnetic competibility 19	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Protection against electric strength 10.9 Incorporation of exitating devices and components 10.9 Incorporation of switching devices and components 10.9 Incorporation of switching devices and connections 10.9 Incorporation of switching devices and components 10.8 Connections for external conductors 10.9 Incorporation of switching devices and components 10.10 Incorporation of switching devices and components 10.11 Short-circuit rating 10.12 Electromagnetic composibility 10.13 Mechanical function 10.14 Electromagneti	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Dear not apply, since the entire switchgear needs to be evaluated. 10.4 Dear not apply, since the entire switchgear needs to be evaluated. 10.5 Protection assemblies 10.5 Protection against electric shock 10.5 Protection of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Features Additional quipment possible Special features Additional quipment possible Age Additional carrying capacity Age Les the panel builter is responsibility. The specifications for the switchgear must be observed. Additional quipment possible Additional quipment possible Additional carrying capacity Used with	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.26 Mechanical impact 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Current limiting class Features Special features Used with AZ Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Internal electrical circuits and connections Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder is responsibility. The panel builder is responsibility. The panel builder is responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Current limiting class Features Additional equipment possible Ambient temperature pint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with	10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Features Special features Additional equipment possible Additional equipment possible Additional equipment possible Additional equipment possible Apz	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Current limiting class Features Special features Additional equipment possible Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Current limiting class Features Additional equipment possible Additional equipment possible Special features Additional equipment possible Additional equipment possible	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Special features Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Current limiting class Features Additional equipment possible Additional equipment possible Current limiting class Special features Additional equipment possible Additional equipment possible Current carrying capacity Used with	10.2.7 Inscriptions	Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Special features Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. The panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Current limiting class Special features Additional equipment possible Special features Additional equipment possible Used with AZ	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Current limiting class Features Additional equipment possible Special features Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder is responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Additional equipment possible Additional equipment possible Special features Additional equipment possible Augustion to a panel builder's responsibility. Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n provide heat dissipation data for the devices. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 1n panel builder's responsibility. The specifications for the switchgear must be observed. 2n panel builder's responsibility. The specifications for the switchgear must be observed. 2n panel builder's responsibility. The specifications for the switchgear must be observed. 2n panel builder's responsibility. The specifications for the switchgear must be observed. 2n panel builder's responsibility. 2n panel b	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 1o.10 Temperature rise The panel builder's responsibility responsibility. 1o.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1o.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1o.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Additional information Current limiting class Features Additional equipment possible Special features Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Current limiting class Features Special features Special features Is the panel builder's responsibility. Is the panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 3 Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Current limiting class Features Special features Special features Lis the panel builder's responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Additional information Current limiting class 3 Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with		
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical information Current limiting class Features Special features 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. The temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with		
Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Current limiting class Features Special features Special features Is the panel builder's responsibility. The specifications for the switchgear must be observed. 3 Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with	· ' ·	
10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Additional information Current limiting class Special features Special features The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 3 Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with	•	
Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function Eurrent limiting class Special features Special features Special features Used with Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.		The panel builder is responsible for the temperature rise calculation. Eaton will
observed. 10.13 Mechanical function Additional information Current limiting class Features Special features Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with AZ	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be
Additional information Current limiting class Features Special features Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with AZ	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
Current limiting class Features Special features Additional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with AZ	10.13 Mechanical function	
Features Additional equipment possible Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with AZ	Additional information	
Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of current carrying capacity Used with AZ	Current limiting class	3
Used with Current carrying capacity AZ	Features	Additional equipment possible
	Special features	·
	Used with	

Technical data ETIM 9.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss13-27-14-19-01

[AAB905019])	n, device / Miniature ci	ircuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss13-27-14-19-01
Built-in depth	mm	75
Release characteristic		С
Number of poles (total)		3
Number of protected poles		3
Rated current	А	125
Rated voltage	V	400
Rated insulation voltage Ui	V	440
Rated impulse withstand voltage Uimp	kV	4
Rated short-circuit breaking capacity Icn according to EN 60898 at 230 V	kA	0
Voltage type		AC
Rated short-circuit breaking capacity Icn according to EN 60898 at 400 V	kA	0
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 230 V	kA	15
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 400 V	kA	15
Frequency	Hz	50 - 60
Power loss	W	
Current limiting class		3
Flush-mounted installation		No
Concurrently switching neutral conductor		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		4.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 55
Connectable conductor cross section multi-wired	mm²	2.5 - 50
Connectable conductor cross section solid-core	mm²	2.5 - 50
Explosion-proof		No