

Specifications

Eaton 216823

Eaton Moeller® series M22 Illuminated selector switch actuator, RMQ-Titan, With thumb-grip, maintained, 2 positions, White, Bezel: titanium

General specifications

PRODUCT NAME	Eaton Moeller® series M22 Illuminated selector switch actuator
CATALOG NUMBER	216823
EAN	4015082168230
PRODUCT LENGTH/DEPTH	46 mm
PRODUCT HEIGHT	30 mm
PRODUCT WIDTH	30 mm
PRODUCT WEIGHT	0.013 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	UL 508 IEC 60947-5 EN 60947-5 CSA Std. C22.2 No. 94-91 CSA Std. C22.2 No. 14-05 CSA Class No.: 3211-03 CSA-C22.2 No. 14-05 IEC/EN 60947-5 UL File No.: E29184 CE CSA CSA File No.: 012528 UL VDE 0660 CSA-C22.2 No. 94-91 IEC/EN 60947 UL Category Control No.: NKCR
MODEL CODE	M22-WRLK-W



Powering Business Worldwide

Features & Functions

BEZEL COLOR	Titanium
BEZEL MATERIAL	Plastic
COLOR	White
DESIGN	With thumb-grip
FITTED WITH:	Front ring
FUNCTIONS	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y

Ambient conditions, mechanical

MOUNTING POSITION	As required
SHOCK RESISTANCE	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Communication

CONNECTION TO SMARTWIRE-DT	With SWD-RMQ connections Yes
-----------------------------------	---------------------------------

Contacts

FORCE FOR POSITIVE OPENING - MIN	0 N
---	-----

General

DEGREE OF PROTECTION	NEMA 4X, 13
DEGREE OF PROTECTION (FRONT SIDE)	IP66
LIFESPAN, MECHANICAL	100,000 Operations
OPENING DIAMETER	22.5 mm
OPERATING FREQUENCY	2000 Operations/h
OPERATING TORQUE	0.3 Nm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ-Titan
SIZE	Front diameter: 29.7 mm
SUITABLE FOR	Illumination
SWITCHING ANGLE	60 °
TYPE	Illuminated selector switch actuator

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Actuator

ACTUATOR COLOR	Black
ACTUATOR FUNCTION	Maintained Switching function latching
ACTUATOR TYPE	Toggle
NUMBER OF SWITCH POSITIONS	2

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W

HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR	Is the panel builder's

EXTERNAL CONDUCTORS	responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

CATALOGUES

[eaton-rmq-titan-brochure-br047004en-en-us.pdf](#)

[Flip catalog - Product Range Catalog - Command and indication](#)

DECLARATIONS OF CONFORMITY

[DA-DC-00004135.pdf](#)

[DA-DC-00004157.pdf](#)

DRAWINGS

[eaton-operating-switch-m22-dimensions-002.eps](#)

[eaton-operating-switch-m22-dimensions.eps](#)

[eaton-general-m22-standards.eps](#)

[eaton-operating-button-symbol-013.eps](#)

[eaton-general-m22-symbol.eps](#)

[eaton-general-approval-m22-symbol.eps](#)

ECAD MODEL

[ETN.216823.edz](#)

FLYERS

[eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf](#)

INSTALLATION INSTRUCTIONS

[IL04716002Z](#)

INSTALLATION VIDEOS

[RMQ Flat Design](#)

MCAD MODEL

[DA-CD-wahltaste_knebel](#)

[DA-CS-wahltaste_knebel](#)

MULTIMEDIA

[easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator](#)

[RMQ small E-Stop emergency-stop button](#)

[MCI MultiColor Light Indicator RMQ compact solution](#)

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

SALES NOTES

[eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf](#)

[eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf](#)

[eaton-rmq-mci-multicolor-light-indicator-flyer-fl047005en-en-us.pdf](#)

[eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf](#)

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc

Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

Follow us on social media to get the latest product and support information.



© 2025 Eaton. All Rights Reserved.