

Specifications

Photo is representative

Eaton 216812

Eaton Moeller® series M22 Illuminated selector switch actuator, RMQ-Titan, With thumb-grip, momentary, 2 positions, White, Bezel: titanium

General specifications

PRODUCT NAME	Eaton Moeller® series M22 Illuminated selector switch actuator
CATALOG NUMBER	216812
EAN	4015082168124
PRODUCT LENGTH/DEPTH	46 mm
PRODUCT HEIGHT	30 mm
PRODUCT WIDTH	30 mm
PRODUCT WEIGHT	0.013 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	IEC 60947-5 CSA Std. C22.2 No. 94-91 EN 60947-5 CSA Std. C22.2 No. 14-05 UL 508 VDE CSA Class No.: 3211-03 CSA-C22.2 No. 94-91 IEC/EN 60947 CSA File No.: 012528 UL File No.: E29184 UL UL Category Control No.: NKCR CE CSA CSA-C22.2 No. 14-05 VDE 0660 IEC/EN 60947-5
MODEL CODE	M22-WLK-W

Features & Functions

BEZEL COLOR	Titanium
BEZEL MATERIAL	Plastic
COLOR	White
DESIGN	With thumb-grip
FITTED WITH:	Front ring
FUNCTIONS	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y

Ambient conditions, mechanical

MOUNTING POSITION	As required
SHOCK RESISTANCE	30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27

Communication

CONNECTION TO SMARTWIRE-DT	With SWD-RMQ connections Yes
-----------------------------------	---------------------------------

Contacts

FORCE FOR POSITIVE OPENING - MIN	0 N
---	-----

General

ACCESSORIES	Thumb grip
DEGREE OF PROTECTION	NEMA 4X, 13
DEGREE OF PROTECTION (FRONT SIDE)	IP66
LIFESPAN, MECHANICAL	100,000 Operations
OPENING DIAMETER	22.5 mm
OPERATING FREQUENCY	2000 Operations/h
OPERATING TORQUE	0.3 Nm
OVERVOLTAGE CATEGORY	III
POLLUTION DEGREE	3
PRODUCT CATEGORY	RMQ-Titan
SIZE	Front diameter: 29.7 mm
SUITABLE FOR	Illumination
SWITCHING ANGLE	40 °
TYPE	Illuminated selector switch actuator

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Actuator

ACTUATOR COLOR	Black
ACTUATOR FUNCTION	Momentary Spring-return
ACTUATOR TYPE	Toggle
NUMBER OF SWITCH POSITIONS	2

Design verification

EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
---	-----

HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS	Is the panel builder's responsibility.

AND CONNECTIONS	
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

CATALOGUES

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

[eaton-rmq-titan-brochure-br047004en-en-us.pdf](#)

[Flip catalog - Product Range Catalog - Command and indication](#)

DECLARATIONS OF CONFORMITY

[DA-DC-00004135.pdf](#)

[DA-DC-00004157.pdf](#)

DRAWINGS

[eaton-operating-switch-m22-dimensions-002.eps](#)

[eaton-operating-switch-m22-dimensions.eps](#)

[eaton-general-m22-standards.eps](#)

[eaton-general-approval-m22-symbol.eps](#)

[eaton-general-m22-symbol.eps](#)

[eaton-operating-button-symbol-013.eps](#)

ECAD MODEL

[ETN.216812.edz](#)

FLYERS

[eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf](#)

INSTALLATION INSTRUCTIONS

[IL04716002Z](#)

INSTALLATION VIDEOS

[RMQ Flat Design](#)

MCAD MODEL

[DA-CS-wahltaste_knebel](#)

[DA-CD-wahltaste_knebel](#)

MULTIMEDIA

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

[MCI MultiColor Light Indicator RMQ compact solution](#)

[RMQ small E-Stop emergency-stop button](#)

[easyE4 SmartWire-DT
module with Remote
Touch Display and RMQ
multi color indicator](#)

SALES NOTES

[eaton-control circuit-
devices rmq-titan-
fl144090en-en-us.pdf](#)

[eaton-rmq-small-e-stop-
flyer-fl047006en-en-us.pdf](#)

[eaton-rmq-flat-enclosure-
flyer-fl047003en-en-us.pdf](#)

[eaton-rmq-mci-multi-
color-light-indicator-flyer-
fl047005en-en-us.pdf](#)

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc

Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

