Specifications

Photo is representative

Eaton 262510

Eaton Moeller® series M22 Accessory Contact element, 1 N/C, 1 N/CL, Front fastening, Cage Clamp, Single contact, Front fixing

| General specifications | |
|-------------------------|--|
| PRODUCT NAME | Eaton Moeller® series M22 Accessory Contact element |
| CATALOG NUMBER | 262510 |
| EAN | 4015082625108 |
| PRODUCT LENGTH/DEPTH | 38 mm |
| PRODUCT HEIGHT | 10 mm |
| PRODUCT WIDTH | 32 mm |
| PRODUCT WEIGHT | 0.01 kg |
| CERTIFICATIONS | CSA-C22.2 No. 14-05 CSA-C22.2 No. 94-91 UL Category Control No.: NKCR CSA File No.: 012528 CSA Class No.: 3211-03 IEC/EN 60947-5 UL 508 IEC 60947-5-1 UL File No.: E29184 CE CSA |
| CATALOG NOTES | Contacts with safety function, by positive opening to IEC/EN 60947-5-1 |
| MODEL CODE | M22-CK01D |



| Features & Functions | |
|--------------------------|-------------------------|
| ELECTRIC CONNECTION TYPE | Spring clamp connection |

| General | |
|--|--|
| DEGREE OF PROTECTION | IP20 |
| LIFESPAN, ELECTRICAL | 1,000,000 Operations (at 230 V, AC-15, 1 A) 700,000 Operations (at 230 V, AC-15, 3 A) 1,200,000 Operations (at 12 V, DC-13, 2.8 A) 1,600,000 Operations (at 230 V, 0.5 A) |
| LIFESPAN, MECHANICAL | 5,000,000 Operations |
| MODEL | Top mounting |
| MOUNTING METHOD | Front fastening |
| OPERATING FREQUENCY | 3600 Operations/h |
| OVERVOLTAGE CATEGORY | III |
| POLLUTION DEGREE | 3 |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) | 6000 V AC |

| Ambient conditions, mechanical | |
|--------------------------------|---|
| SHOCK RESISTANCE | 30 g, Mechanical, according to IEC/EN 60068-2-27, Shock duration 11 ms |

| Climatic environmental conditions | |
|--|--|
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT OPERATING TEMPERATURE - MAX | 70 °C |
| AMBIENT STORAGE TEMPERATURE - MIN | -25 °C |
| AMBIENT STORAGE TEMPERATURE - MAX | 85 °C |
| CLIMATIC PROOFING | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |

| Terminal capacities | |
|---|----------------|
| TERMINAL CAPACITY (FLEXIBLE WITH FERRULE) | 0.5 - 1.5 mm² |
| TERMINAL CAPACITY (SOLID) | 0.75 - 2.5 mm² |
| TERMINAL CAPACITY (STRANDED) | 0.5 - 2.5 mm² |

| Electrical rating | |
|--|-------|
| RATED INSULATION VOLTAGE (UI) | 500 V |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 115 V | 6 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V | 6 A |
| RATED OPERATIONAL | 4 A |

| CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V | |
|---|-------|
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 500 V | 2 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 110 V | 0.6 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 220 V, 230 V | 0.3 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 24 V | 3 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 42 V | 1.7 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 60 V | 1.2 A |

| Short-circuit rating | |
|--|---|
| RATED CONDITIONAL SHORT-CIRCUIT CURRENT (IQ) | 1 kA |
| SHORT-CIRCUIT PROTECTION | PKZM0-10/FAZ-B6/1, Contacts, Max. short- circuit protective device, Fuseless |
| SHORT-CIRCUIT PROTECTION RATING | Max. 10 A gG/gL, Fuse, Contacts |

| Communication | |
|----------------------------|--|
| CONNECTION TO SMARTWIRE-DT | No |
| CONNECTION TYPE | Single contact Front fixing Cage Clamp |
| | |

Contact

| Actuator | |
|--|--------|
| ACTUATING FORCE - MAX | 5 N |
| ACTUATOR TRAVEL AND ACTUATION FORCE (DIN EN 60947-5-1) | 4.8 mm |
| KNOB TRAVEL | 5.7 mm |
| , | 5.7 mm |

| Tontal Circuit CONTROL CIRCUIT RELIABILITY 1 failure per 5,000,000 switching operations (statistically determined, at 5 V DC/1 mA) 1 failure per 10,000,000 switching operations (Statistically determined, at 24 V DC/5 mA) FORCE FOR POSITIVE OPENING - MIN NUMBER OF CONTACTS (CHANGE-OVER CONTACTS) NUMBER OF CONTACTS (NORMALLY CLOSED 1 failure per 5,000,000 switching operations (Statistically determined, at 24 V DC/5 mA) 0 15 N NUMBER OF CONTACTS (NORMALLY CLOSED | Contacts | |
|---|--------------|--|
| OPENING - MIN NUMBER OF CONTACTS (CHANGE-OVER 0 CONTACTS) NUMBER OF CONTACTS 1 | | switching operations (statistically determined, at 5 V DC/1 mA) 1 failure per 10,000,000 switching operations (Statistically determined, |
| (CHANGE-OVER 0 CONTACTS) NUMBER OF CONTACTS | | 15 N |
| 1 | (CHANGE-OVER | 0 |
| | | 1 |

CONTACTS)

NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)

0

| Design verification | |
|---|--|
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID | 0 W |
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID | 0.11 W |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 6 A |
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS | 0 W |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| | |

| | Resources | |
|----------------------|------------------------------|--|
| | | eaton-pushbuttons-signal- towers-sensors-assortment- overview-catalog-ca047003en- en-us.pdf |
| | CATALOGUES | eaton-rmq-titan-brochure- br047004en-en-us.pdf |
| | | Flip catalog - Product Range Catalog - Command and indication |
| | CERTIFICATION REPORTS | <u>000Z425</u> |
| | CONTROL TRAVI | eaton-operating-diagram-m22- contact-element-contact- travel-diagram.eps |
| | | DA-DC-00004975.pdf |
| nts. | | <u>DA-DC-00004176.pdf</u> |
| | DECLARATIONS OF CONFORMITY | OF <u>DA-DC-00004135.pdf</u> |
| nts. | | DA-DC-00004157.pdf |
| | | DA-DC-00004134.pdf |
| nts. | | DA-DC-00004971.pdf |
| nts. | DRAWINGS | eaton-operating-actuation- m22-led-element- dimensions.eps |
| | | eaton-operating-contact-m22- contact-element-3d-drawing- 004.eps |
| nts. | | eaton-general-standards- 000Z425.jpg |
| the ds to | | eaton-operating-devices- adapter-flow-diagram-003.eps |
| the | ECAD MODEL | ETN.262510.edz |
| ds to | FLYERS | eaton-rmq-titan-selection-aid- brochure-fl047002-en-us.pdf |
| nts. the ds to | INSTALLATION INSTRUCTIONS | eaton-operating-devices-rmq- titan-m22-instruction-leaflet- il047018zu.pdf |
| | | <u>IL04716002Z</u> |
| nts | INSTALLATION VIDEOS | RMQ Flat Design |
| nts. the | MCAD MODEL | kontaktelement cage front |
| ds to | | kontaktelement cage front.stp |

| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS Does not apply, since the entire switchgear needs to be evaluated. 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS Is the panel builder's responsibility. 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS Is the panel builder's responsibility. 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH Is the panel builder's responsibility. 10.9.3 IMPULSE WITHSTAND VOLTAGE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL Is the panel builder's responsibility. 10.10 TEMPERATURE RISE The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. | | |
|--|------------------------|---|
| ELECTRICAL CIRCUITS AND CONNECTIONS 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION Is the panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | SWITCHING DEVICES AND | entire switchgear needs to |
| 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH 10.9.3 IMPULSE Is the panel builder's responsibility. 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION Is the panel builder's responsibility. Is the panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | ELECTRICAL CIRCUITS | - |
| Sthe panel builder's responsibility. | | · |
| WITHSTAND VOLTAGEresponsibility.10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIALIs the panel builder's responsibility.10.10 TEMPERATURE RISEThe panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.10.11 SHORT-CIRCUIT RATINGIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 ELECTROMAGNETIC COMPATIBILITYIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 MECHANICAL FUNCTIONThe device meets the requirements, provided the information in the instruction leaflet (IL) is | FREQUENCY ELECTRIC | - |
| Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | | - |
| 10.10 TEMPERATURE RISE responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | ENCLOSURES MADE OF | - |
| 10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | 10.10 TEMPERATURE RISE | responsible for the temperature rise calculation. Eaton will provide heat dissipation |
| 10.12 ELECTROMAGNETIC COMPATIBILITY responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is | | responsibility. The specifications for the switchgear must be |
| 10.13 MECHANICAL FUNCTION requirements, provided the information in the instruction leaflet (IL) is | | responsibility. The specifications for the switchgear must be |
| | | requirements, provided the information in the instruction leaflet (IL) is |

| | easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator |
|-----------------|--|
| MULTIMEDIA | MCI MultiColor Light Indicator RMQ compact solution |
| | RMQ small E-Stop emergency- stop button |
| | MCI Multicolor Light Indicator M22 with SmartWire-DT |
| | eaton-rmq-small-e-stop-flyer- fl047006en-en-us.pdf |
| | eaton-rmq-flat-enclosure-flyer- fl047003en-en-us.pdf |
| SALES NOTES | eaton-rmq-mci-multi-color- light-indicator-flyer- fl047005en-en-us.pdf |
| | eaton-control circuit-devices rmq-titan-fl144090en-en- us.pdf |
| WIRING DIAGRAMS | eaton-operating-contact-m22- contact-element-wiring- diagram-005.eps |
| | |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc

Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









